



**Power  
Generation**

# EPA Tier 3 Nonroad Emission Compliance Statement C100D6R 60 Hz Diesel Generator Set

## Compliance Information:

The engine used in this generator set meets U.S. EPA emission standards under 40 CFR 1039.625 and California Emission requirements under 13 CCR 2423(D). Selling or installing this engine for any purpose other than for the equipment flexibility provisions cited may be a violation of Federal or California law subject to civil penalty. This engine is certified to operate on diesel fuel only. Constant speed only.

Engine Manufacturer:	Cummins Inc
EPA Certificate Number:	N/A
Effective Date:	01/01/2012
Date Issued:	01/01/2012
EPA Diesel Engine Family:	BCEXL0409AAC
CARB Executive Order:	

## Engine Information:

Model:	Cummins Inc QSB5-G4 NR3	Bore:	4.21 in. (107 mm)
Engine Nameplate HP:	314		
Type:	4 Cycle, In Line, 4 Cylinder Diesel	Stroke:	4.88 in. (124 mm)
Aspiration:	Turbocharged and CAC	Displacement:	409 cu. in. ( 6.7 liters )

## U.S. Environmental Protection Agency Non Road Engines Tier 3 Limits

(All values are Grams per HP-Hour)

<u>COMPONENT</u>	
NOx (Oxides of Nitrogen)	2.0
CO (Carbon Monoxide)	3.5
PM (Particulate Matter)	0.02

Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may result in elevated emission levels.